


Submittal Data Sheet

2 Ton, Ceiling-Mount, Uncased Air Handler ACNF240016

STANDARD FEATURES

- Check flowrater for heat pump and cooling-only applications
- All-Aluminum tube/aluminum fin coil
- Direct-drive, resilient-mount, multi-speed motor
- Sequence-controlled and rust-resistant nickel chromium heating elements of 5, 6, 8 and 10 kW
- High-efficiency evaporator coil
- Quiet operation
- Models with EEM motors: ACNF25 & ACNF31
- Models with PSC motors: ACNF18, ACNF24, & ACNF30
- Available with and without heat
- AHRI Certified
- ETL Listed
- Primary/secondary drain connection in a high-temperature plastic drain pan
- Suitable for free-return installation (non-ducted return air)
- Galvanized-steel construction
- Factory-installed pull-type disconnect
- Easy service access











Submittal Date: 11/29/2017 5:15:18 PM Page 1 of 3



Submittal Data Sheet

2 Ton, Ceiling-Mount, Uncased Air Handler ACNF240016

PERFORMANCE			
Product Model No.	ACNF240016	Product Model Name:	2 Ton, Ceiling-Mount, Uncased Air Handler
Туре:	Air Handler	Cooling Capacity (Nominal) (Btu/hr):	24,000
Blower Motor Rating (HP):	1/4		

PRODUCT DETAILS					
Power Supply (V/Hz/Ph):	208-230 / 60 / 1	Airflow Rate (High / Low) (CFM):	880 / 840		
Min. Circuit Amps MCA (A):	1.6	Suction Valve Connection Size (inch):	3/4		
Max Overcurrent Protection (MOP) (A):	15	Liquid Valve Connection Size (inch):	3/8		
Dimensions (HxWxD) (in):	10 x 43-1/2 x 21	Condensate Connection (inch):	3/4		
Net Weight (lb):	69	Blower Size Diameter (inch):	6.31		
Gross Weight (lb):	69	Blower Size Width (inch):	8.25		


Submittal Date: 11/29/2017 5:15:18 PM Page 2 of 3





Submittal Data Sheet

2 Ton, Ceiling-Mount, Uncased Air Handler ACNF240016

DIMENSIONAL DRAWING







	ACNF18	ACNF24	ACNF25	ACNF30	ACNF31
А	37¼"	43¼"	43¼"	49¼"	49¼"
В	34¾"	40¾"	40¾"	46¾"	46¾"
С	30"	36"	36"	42"	42"
D	6½"	6½"	6½"	6½"	6½"

Daikin North America LLC, 5151 San Felipe, Suite 500, Houston, TX, 77056

Submittal Date: 11/29/2017 5:15:18 PM Page 3 of 3