

DAIKIN ONE+ and TOUCH HOMEOWNER MENU OUTLINE
(based on v4.1 software for unitary and unitary zoning systems)

Level 1	Level 2	Level 3	Level 4	Level 5	Level 6	Level 7
home screen	(mode icon)	(see below)				
	(indoor humidity)	(if enabled)				
	(indoor air quality)	(if enabled)				
	(outdoor temperature)	(if enabled)				
	(outdoor humidity)	(if enabled)				
	(outdoor air quality)	(if enabled)				
	(room temperature)					
	(csp and cooler/down icon)					
	(hsp and warmer/up icon)					
	(thermostat name)					
	(status messages)	(if any)				
	(critical error messages)	(if any)				
schedule screen	(see below)					
away screen	away csp and hsp					
air quality screen	room temperature					
	outdoor temp					
	outdoor humidity					
	weather forecast					
	circulate air (selection)	off				
		always on				
		on a schedule				
	speed	low				
		medium				
		high				
	one clean	off				
		on				
	system mode	auto (cool & heat)				
		cool				
		heat				
		off				
		emergency heat	(if HP and another heat source)			
	schedule	paused until...	(if schedule paused)			
		on				
		off				
		edit schedule	Sunday Monday Tuesday Wednesday Thursday Friday Saturday	(1st schedule event name)	day (weekday of event)	
				start time	time	(time selection)
				heat setpoint/cool setpoint	label	(text entry)
					action	set temperature
					temperature	(selection of heat and cool setpoints)
				(2nd schedule event name)		
				start time	(same options as 1st schedule event)	
				heat setpoint/cool setpoint		
				(up to 6 schedule events)		
				copy day		
				add event		
		override duration	until next event			
			for one hour			
			for two hours			
			for four hours			
			for eight hours			
	away	on (radio button)				
		off (radio button)				
		away temperatures	setpoints)			
		receive geofencing events (checkbox)				
	display	language	english español française			
		degree units	fahrenheit celsius			
		brightness	50 - 100% scale			
		night mode	night mode (check box) from (time selection) to (time selection)			
		use large font (check box)				
		use light bar (check box)				
		screen saver	off blank screen analog clock digital clock			
		screen cleaning	touch screen is disabled for cleaning (30s)			
		lock	Enter a 4-digit PIN...	(number entry)		
	sound	use sound (check box)	(only older One+ thermostats)			
		quiet mode (off or hours if enabled) (if unit supports quiet mode and not hidden by installer)	use quiet mode quiet hours	(check box) from: (time) to: (time) (time selection in 15 min. increments)		
	reminders	(list of installed reminder type with following menu for each)	Off			
			1 month			
			2 months			
			3 months			
			4 months			
			6 months			
			12 months			
			restart timer	cancel continue		
		time zone	with radio buttons; cannot be changed if connected to internet and app)			

Settings

date & time	month/date/year	be changed if connected to internet)				
	hour/minute/am or pm	(selection with spinner, cannot be changed if connected to				
	use 24-hour time format (checkbox)					
wifi	use wifi (checkbox)					
	networks (current network)	network list	legal notices	terms of use	(text)	
				privacy policy	(text)	
				end user license agreement	(text)	
				decline		
				accept		
		(password text box)				
		show password (checkbox)	(if protected network)			
		advanced settings	use dhcp (checkbox)			
		connect per agreed terms (and) Done	(initiates connection to wifi network)			(screen appears after legal notices accepted)
		searching for networks (or) search again				
		local API enabled (checkbox)				
		internet connected (check)				
		Daikin One Cloud connected (check)				
account		terms of use	(text)			
		privacy policy	(text)			
		end user license agreement	(text)			
		restart thermostat (if internet but no cloud)				
air quality	(6-digit account code if app not connected)					
	(account email if app connected)					
	reset registration (if app connected)	cancel continue				
humidity	circulate air (selection)	off	(radio buttons)			
		always on				
		on a schedule				
		speed	low medium high	(if "always on" or "on a schedule" selected)		
		schedule (selected time)	from (time) to (time)			
	duration	for entire schedule				
		hourly for 5 minutes				
		hourly for 15 minutes				
		hourly for 30 minutes				
		hourly for 45 minutes				
one clean	Off On					
cool/heat	target humidity	humidify if less than (25% - 65%) dehumidify if more than (35% - 75%)	(5% increments) (5% increments)			
	disable humidification	(checkbox)				
	overcool to dehumidify	Overcooling allowed to dehumidify: Temperature setpoint deadband:	(1°F or 0.5°C increments) (1°F or 0.5°C increments)			
	overcool to dehumidify	Overcooling allowed to dehumidify: 0, 1, 2, or 3°F (0, 0.5, 1, or 1.5°C) Temperature setpoint dead band: 2°F to 9°F in 1°F steps (0°C to 5°C in 0.5°C steps)				
energy	disable humidification	(checkbox)				
	enable tight setpoint control	(checkbox)				
	demand response	use demand response (checkbox)	(only functional with local utility support)			
When demand response signal is received: offset temperature setpoints fixed temperature setpoints		(radio buttons)				
response settings		setpoint offsets	Offset heat setpoints by this value: (-1°F to -7°F) Offset cool setpoints by this value: (1°F to 7°F)			
		event setpoint limits	(50°F to 90°F)			
		enable energy pricing (checkbox)	price trigger (if checkbox above) (\$0.00 to \$9.99)			
thermostat	name	main room				
		upstairs				
		downstairs				
		hallway				
		bedroom				
		kitchen				
		other				
		other name (if other selected)	(text entry)			
	model ONEPLUS					
	software version (x.x.x format)					
	wifi address (x:x:x:x:x format)					
	thermostat ID (DKN...)					
	node address (if zoning)					
	node type (if zoning)					
restart thermostat	cancel continue					
check for update	software update found (or) no update available--dismiss					
COMMUNICATING EQUIPMENT:						

equipment	air conditioner (model, if present) (or) heat pump (model, if present)	(model details)			
		specifications	(list of model specifications)		
		quiet mode (off or hours if enabled) (if unit supports quiet mode)	use quiet mode	(check box)	
			quiet hours	from: (time) to: (time) (in 15 min. increments)	
		prioritize efficiency (or) prioritize comfort (if heat pump and furnace system)	(radio buttons)		
		air handler (model)(if present) (or)	(model details)		
		EEV coil (if present)	specifications	(list of model specifications)	
			(list of model specifications)		
		zone board (model)	specifications	model name	
				board ID	
			firmware version		
	ADDITIONAL EQUIPMENT:				
	remote sensors	include thermostat (temp/hum values)	(check box)		
		(sensor name) (temp/hum values)	sensor name	(text entry)	
			sensor type	surface mount	
			signal strength (acceptable, marginal, or low)	(bar displaying signal strength)	
			cancel		
			save		
		(sensor name) (temp/hum	(similar, up to 8 sensors)		
		air quality sensor	(if installed)		
		electronic filter	(if installed)		
		media filter	(if installed)		
	UV bulbs	(if installed)			
	aux heat source	(if installed)			
	humidifier	(if installed)			
	dehumidifier	(if installed)			
	zone board	(if installed)			
	support	Daikin Support	(Daikin contact information)		
		Daikin Dealer	(if dealer information entered)		
		cloud services	no access		
			view only		
	dealer edit	cancel	(i)	(4 digit code for thermostat)	
		continue	4 digit code (text entry)		
			unlock thermostat (or) done	(entry into commissioning screens)	