

DAIKIN ONE+ and TOUCH HOMEOWNER MENU OUTLINE
(based on v3.9 software for unitary systems)

Level 1	Level 2	Level 3	Level 4	Level 5	Level 6	Level 7
home screen	mode icon	(see below)				
	room relative humidity					
	room temperature					
	csp and cooler/down icon					
	hsp and warmer/up icon					
	thermostat name field					
	critical error messages	(if any)				
schedule screen	status messages					
	(see below)					
air quality screen	away screen	away csp and hsp				
	room temperature					
	outdoor temp					
	outdoor humidity					
	weather forecast					
	circulate air (selection)	off always on on a schedule	speed low medium high			
	one clean	off on				
system mode	system mode	auto (cool & heat)				
		cool				
		heat				
		off				
		emergency heat	(if HP and another heat source)			
	schedule	paused until...	(if schedule paused)			
		on				
		off				
		edit schedule	Sunday Monday Tuesday Wednesday Thursday Friday Saturday	(1st schedule event name) start time heat setpoint/cool setpoint (2nd schedule event name) start time heat setpoint/cool setpoint (up to 6 schedule events) copy day add event	day (weekday of event) time label action temperature	(time selection) (text entry) set temperature (selection of heat and cool setpoints)
		override duration	until next event for one hour for two hours for four hours for eight hours			
		away	on (radio button) off (radio button) away temperatures receive geofencing events (checkbox)			
	display	language	english español française			
		degree units	fahrenheit celsius			
		brightness	50 - 100% scale			
		night mode	night mode (check box) from (time selection) to (time selection)			
		use large font (checkbox)				
		use light bar (checkbox)				
		screen saver	off blank screen analog clock digital clock			
		screen cleaning	touch screen is disabled for cleaning (30s)			
		lock	Enter a 4-digit PIN...	(number entry)		
		sound	use sound (checkbox) quiet mode (off or hours if enabled) (if unit supports quiet mode and not hidden by installer)	(not the Touch thermostat) use quiet mode quiet hours	(check box) from: (time) to: (time) (time selection in 15 min. increments)	
reminders	(list of installed reminder type with following menu for each)	Off				
		1 month				
		2 months				
		3 months				
		4 months				
		6 months				
		12 months				
date & time	time zone	restart timer	cancel continue			
		with radio buttons; cannot be changed if connected to internet and app)				
		be changed if connected to internet)				
	month/date/year					
date & time	hour/minute/am or pm	(selection with spinner, cannot be changed if connected to				

	use 24-hour time format (checkbox)				
	use wifi (checkbox)				
				terms of use (text)	
				privacy policy (text)	
				end user license agreement (text)	
				decline	
				accept	
				(password text box)	
				show password (checkbox)	(if protected network)
				advanced settings	use dhcp (checkbox)
				connect per agreed terms (and) Done	(initiates connection to wifi network)
				searching for networks (or) search again	
	internet connected (check)				
	Daikin One Cloud connected (check)				
				terms of use (text)	
				privacy policy (text)	
				end user license agreement (text)	
	restart thermostat (if internet but no cloud)				
	(6-digit account code if app not connected)				
	(account email if app connected)				
	reset registration (if app connected)	cancel			
		continue			
Settings	air quality	off			
		always on	(radio buttons)		
		on a schedule			
		speed	low medium high	(if "always on" or "on a schedule" selected)	
		schedule (selected time)	from (time) to (time)		
		duration	for entire schedule hourly for 5 minutes hourly for 15 minutes hourly for 30 minutes hourly for 45 minutes	(radio buttons)	(if "on a schedule" selected)
		one clean	Off On		
		target humidity	humidify if less than (25% - 65%) dehumidify if more than (35% - 75%)	(5% increments)	
		disable humidification	(checkbox)		
		overcool to dehumidify	Overcooling allowed to dehumidify: Temperature setpoint deadband:	(1°F or 0.5°C increments)	
cool/heat		overcool to dehumidify	Overcooling allowed to dehumidify: 0, 1, 2, or 3°F (1°C, 2°C, 5°C)		
			Temperature setpoint dead band: 2°F to 9°F in 1°F steps (0°C to 5°C in 0.5°C steps)		
		disable humidification	(checkbox)		
		enable tight setpoint control	(checkbox)		
energy	demand response	use demand response (checkbox)	(only functional with local utility support)		
		When demand response signal is received:			
		offset temperature setpoints	(radio buttons)		
		fixed temperature setpoints			
				setpoint offsets	Offset heat setpoints by this value: (1°F to -7°F)
					Offset cool setpoints by this value: (1°F to 7°F)
		response settings		event setpoint limits	(50°F to 90°F)
				enable energy pricing (checkbox)	
				price trigger (if checkbox above)	(\$0.00 to \$9.99)
thermostat		main room			
		upstairs			
		downstairs			
		hallway			
		bedroom			
		kitchen			
		other			
		other name (if other selected)	(text entry)		
		model ONEPLUS			
		software version (x.x.x format)			
		wifi address (xxxx:xx:xx format)			
		thermostat ID (DKN...)			
		restart thermostat	cancel continue		
		check for update	software update found (or) no update available--dismiss		
		COMMUNICATING EQUIPMENT:			
		(model details)			
		specifications	(list of model specifications)		
		quiet mode (off or hours if enabled)	use quiet mode (check box)		
		(if unit supports quiet mode) (or)	quiet hours (from: (time) to: (time) (in 15 min. increments)		

equipment	heat pump (model, if present)	prioritize efficiency (or) prioritize comfort (if heat pump and furnace system)	(radio buttons)		
	air handler (model)(if present) (or)	(model details) specifications	(list of model specifications)		
	EEV coil (if present)	(list of model specifications)			
	ADDITIONAL EQUIPMENT:				
		include thermostat (temp/hum values)	(check box)		
	remote sensors		sensor name	(text entry)	
			sensor type	surface mount	
		(sensor name) (temp/hum values)	signal strength (acceptable, marginal, or low)	(bar displaying signal strength)	
			cancel		
			save		
		(sensor name) (temp/hum values)	(similar, up to 8 sensors)		
	air quality sensor	(if installed)			
	electronic filter	(if installed)			
	media filter	(if installed)			
	UV bulbs	(if installed)			
	aux heat source	(if installed)			
	humidifier	(if installed)			
	dehumidifier	(if installed)			
	zone board	(if installed)			
support	Daikin Support	(Daikin contact information)			
	Daikin Dealer	(if dealer information entered)			
		no access			
	cloud services	view only			
dealer edit	cancel	(i)	(4 digit code for thermostat)		
		4 digit code (text entry)			
	continue	unlock thermostat (or) done	(entry into commissioning screens)		