

Daikin One Lite Local Thermostat Menu Outline

Level 1	Level 2	Level 3	Comments
(room temperature)			display only
(mode button) (options depend on available modes)	OFF		
	HEAT		
	COOL		
	AUTO		
	EMERGENCY HEAT		
(fan button)	FAN OFF		
	FAN ON		
(cooler/down button)	(lower setpoint(s) by 1°F/0.5°C)		
(warmer/up button)	(raise setpoint(s) by 1°F/0.5°C)		
(mode indicator LED)	off, red (heating), or green (cooling)		
FAN SETTINGS (press and hold fan button for 2s, MODE button to advance through options, up and down to select value)	COOL FAN SPEED	1, 2, 3, 4, 5, A (AUTO)	
	COOL VERTICAL SWING	OFF, ON	
	COOL HORIZONTAL SWING	OFF, ON	
	HEAT FAN SPEED	1, 2, 3, 4, 5, A (AUTO)	
	HEAT VERTICAL SWING	OFF, ON	
	HEAT HORIZONTAL SWING	OFF, ON	
SCHEDUL (press the fan and warmer/up for 2s, MODE button to advance through options, up and down to select value)	SCHEDULE USE THE WARMER/COOLER BUTTONS TO ENABLE SCHEDULE USE THE MODE BUTTON FOR SETUP	OFF, ON	
	SET THE SCHEDULE USE THE WARMER/COOLER BUTTONS TO CYCLE THROUGH THE OPTIONS USE THE MODE BUTTON TO ADVANCE		
	SELECT DAY OF WEEK TO SCHEDULE	MONDAY, TUESDAY, WED, THURS, FRIDAY, SAT, SUNDAY	
	MONDAY MORNING ENABLE	OFF, ON	
	Morning Start	(time selection in 15 minute increments)	(if morning enabled)
	Morning COOL	(cool setpoint selection)	(if morning enabled)
	Morning HEAT	(heat setpoint selection)	(if morning enabled)
	MONDAY DAY ENABLE	OFF, ON	
	Day Start	(time selection in 15 minute increments)	(if day enabled)
	Day COOL	(cool setpoint selection)	(if day enabled)
	Day HEAT	(heat setpoint selection)	(if day enabled)
	MONDAY EVENING ENABLE	OFF, ON	
	Evening Start	(time selection in 15 minute increments)	(if evening enabled)
	Evening COOL	(cool setpoint selection)	(if evening enabled)
	Evening HEAT	(heat setpoint selection)	(if evening enabled)
	MONDAY NIGHT ENABLE	OFF, ON	
	Night Start	(time selection in 15 minute increments)	(if night enabled)
	Night COOL	(cool setpoint selection)	(if night enabled)
	Night HEAT	(heat setpoint selection)	(if night enabled)

	(...repeat for remaining days of week)			
LOCK (mode, up, and down for 3 s)	(lock icon)			
AWAY (press and hold fan and cooler/down buttons for 2 seconds, MODE button to advance through options, up and down to select value)	AWAY USE THE WARMER/COOLER BUTTONS TO ENABLE AWAY USE THE MODE BUTTON FOR SETUP SET THE AWAY SETPNTS USE THE MODE BUTTON TO ADVANCE THROUGH THE MODES	OFF, ON (leaf displayed)		
	COOL (leaf)	(select the away cool setpoint)		
	HEAT (leaf)	(select the away heat setpoint)		
SETUP (press mode and fan buttons for 5s, MODE button to advance through options, up and down to select value)	1 CLOCK (if no internet connection)	(adjust time up or down)		
	2 DAY (if no internet connection)	Su, Mo, Tu, We, Th, Fr, or Sa		
	3 BACKLIGHT	OFF, ON		
	4 NIGHTLT	OFF, ON		
	5 NIGHTMD Start	(+15 min to start time) (-15 min from start time)		
	6 NIGHTMD Stop	(+15 min to stop time) (-15 min from stop time)		
	7 LIGHT BAR	OFF, ON		
	8 SHOW CLOCK	OFF, ON		
	9 Filter	(time since reset, press FAN to reset)		
	10 Service Filter	(time until reminder)		
	11 F/C	F (Fahrenheit) or C (Celsius)		
	12 S21	(equipment protocol)		
	14 UNIT TYPE	WALL, CEILING, SINGLE, FLOOR, or DUCTED		
	15 AUX HEAT	OFF, ON		
	16 SECOND/PRIMARY (If AUX heat secondary)			
	17 ENABLE HEAT PUMP LOCKOUT	OFF, ON		
	18 HEAT PUMP LOCKOUT TEMP	-20°F to 65°F in 5°F steps (-27.5°C to 17.5°C in 2.5°C steps).		
	19 ENABLE AUX HEAT LOCKOUT	OFF, ON		
	20 AUX HEAT LOCKOUT TEMP	-10°F to 75°F in 5°F increments (-22.5°C to 22.5°C in 2.5°C steps).		
	21 T ON	-7°F to -3°F in 1°F steps (-4.0°C to -1.5 to in 0.5°C steps)		
	22 T OFF	-4°F to 1°F in 1°F steps (-2°C to 0.5°C in 0.5°C steps).		
	(if AUX heat primary)			
	17 ENABLE HEAT PUMP LOCKOUT	OFF, ON		
	18 HEAT PUMP LOCKOUT TEMP	-20°F to 65°F in 5°F steps (-27.5°C to 17.5°C in 2.5°C steps).		
	23 SP DIFF	-9°F, -7°F, -5°F, -4°F, or -2°F (-5°C to -1°C in 1°C steps)		
	24 T ON	-2 or -1°F (-1.0 or -0.5°C).		
	25 T OFF	1°F (0.5°C)		display only

	26 MAX SETPOINT	52 to 90°F in 1°F steps (11 to 32°C in 0.5°C steps)		
	27 MIN SETPOINT	50 to 88°F in 1°F steps (10 to 31°C in 0.5°C steps)		
	28 DEADBND	2°F to 9°F in 1°F steps (1°C to 5°C in 0.5°C steps)		
WIRELSS SETUP MENU (press FAN button for 5s, MODE button to advance through options, up and down to select value)	WIRELSS SETUP MENU PRESS COOLER TO CONFIGURE WIFI PRESS WARMER TO PAIR WITH DAIKIN ONE CLOUD PRESS MODE FOR INFO	(press cooler/down button)	AP MODE STARTING AP MODE ACTIVE	takes about 10s to become ACTIVE
	ALL ICONS			
	CALIBRATE TEMP	(temperature offset of -7°F to 7°F in 1°F steps)		
	CALIBRATE HUM	(humidity offset of -15% to 15% in 1% steps)		
ALL ICONS (press mode and cooler/down for 5s, MODE button to advance through options, up and down to select value)	VERSION (x.x.x) PRESS AND HOLD FAN BUTTON TO UPDATE FIRMWARE	SEEKING FOR NEW FIRMWRE UPDTING (if new firmware found) -or- NO UPDATE (if none)		
	(reset options)	WIFI RESET PRESS AND HOLD FAN BUTTON ACCOUNT RESET PRESS AND HOLD FAN BUTTON FACTORY RESET PRESS AND HOLD FAN BUTTON		
	RESTART PRESS AND HOLD FAN BUTTON			
	ACCTID (email address, if linked to app)			
	STATID DKNxxxxxxxx			